

# Accessibility Evaluation

## Monroe County Polling Location



**Bloomington High School North 3901 N Kinser  
Pike Bloomington, IN 47404**

**Inspection Date: 03/23/2026**

**Inspectors: Michael Shermis, Annabelle Vosmeier**

Prepared By  
**Monroe County**  
**(916) 473 - 9444**

**Report Date: 04/06/2026**

## ***Table of Contents***

---

<b>Findings</b>	.....	<b>3</b>
<b>Exterior</b>	.....	<b>3</b>
<b>Parking</b>	.....	<b>3</b>
<b>Path of Travel</b>	.....	<b>4</b>

## Exterior: Parking

### Finding: 1

The access aisle is missing at the accessible parking space.

Access aisles serving parking spaces shall adjoin an accessible route. Two parking spaces shall be permitted to share a common access aisle.

2010 ADAS Section 502.2


Car parking spaces shall be 96 inches (2440 mm) wide minimum and van parking spaces shall be 132 inches (3350 mm) wide minimum, shall be marked to define the width, and shall have an adjacent access aisle complying with 502.3.

### Citation:

2010 ADAS Section: 502.2

### Recommendation:

Recommend marking one or two spaces with cones to create access aisles. There are additional accessible spaces with access aisles slightly farther away from the ramp.



## Exterior: Path of Travel

### Finding: 2

The ramps exceeds the maximum running slope (direction of travel) allowable of 8.33%. The slope was measured at 9 degrees, or approximately 15.8%.

Ramps should have the least possible slope but in no case more than 8.3% (1:12).

2010 ADAS Section 405.2


Ramp runs shall have a running slope not steeper than 1:12.

### Citation:

2010 ADAS Section: 405.2

### Recommendation:

Add signage directing voters to park in the drop-off lane near the front doors if the ramp is too steep for them to climb. Add signage and/or cones in the drop-off lane to identify it as additional accessible parking.



**Finding: 2 Additional Finding Photos**

