

# Accessibility Evaluation

## Monroe County Polling Location



**Unionville Elementary**  
**8144 E State Rd 45**  
**Unionville, IN 47468**

**Inspection Date: 03/17/2026**  
**Inspectors: Michael Bird**

**Prepared By**  
**Monroe County**  
**(916) 473 - 9444**

**Report Date: 04/06/2026**

## ***Table of Contents***

---

<b>Findings</b>	.....	<b>3</b>
<b>Exterior</b>	.....	<b>3</b>
<b>Parking</b>	.....	<b>3</b>
<b>Path of Travel</b>	.....	<b>4</b>
<b>Interior</b>	.....	<b>6</b>
<b>Restrooms</b>	.....	<b>6</b>

## **Exterior: Parking**

### **Finding: 1**

The van space is missing the required van identification sign.

**Parking space identification signs shall include the International Symbol of Accessibility. Signs identifying van parking spaces shall contain the designation "van accessible."**

*2010 ADAS Section 502.6*

*Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation "van accessible." Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.*

### **Citation:**

**2010 ADAS Section: 502.6**

### **Recommendation:**

**Add temporary or permanent van accessible signage.**



## Exterior: Path of Travel

### Finding: 2

The access aisle is not located on an accessible route of travel to the accessible building entrance. An individual parking at the farther accessible space must enter the vehicular way to reach the curb ramp.

Accessible parking spaces serving a particular building shall be located on the shortest accessible route of travel from parking to an accessible entrance. In buildings with multiple accessible entrances with adjacent parking, accessible parking spaces shall be dispersed and located closest to the accessible entrances.

*2010 ADAS Section 208.3.1*

*Parking spaces complying with 502 that serve a particular building or facility shall be located on the shortest accessible route from parking to an entrance complying with 206.4. Where parking serves more than one accessible entrance, parking spaces complying with 502 shall be dispersed and located on the shortest accessible route to the accessible entrances. In parking facilities that do not serve a particular building or facility, parking spaces complying with 502 shall be located on the shortest accessible route to an accessible pedestrian entrance of the parking facility.*

*2010 ADAS Section 502.3*


*Access aisles serving parking spaces shall comply with 502.3. Access aisles shall adjoin an accessible route. Two parking spaces shall be permitted to share a common access aisle.*

### Citation:

**2010 ADAS Section: 208.3.1, 502.3**

### Recommendation:

Place cones to create a protected path of travel from the farther access aisle to the closer access aisle and the curb ramp.



**Finding: 2 Additional Finding Photos**



## **Interior: Restrooms**

### **Finding: 3**

**There are not enough accessible toilet compartments. Where toilet compartments are provided, at least one toilet compartment shall be wheelchair accessible.**

*2010 ADAS Section 213.3.1*

*Where toilet compartments are provided, at least one toilet compartment shall comply with 604.8.1. In addition to the compartment required to comply with 604.8.1, at least one compartment shall comply with 604.8.2 where six or more toilet compartments are provided, or where the combination of urinals and water closets totals six or more fixtures.*

### **Citation:**

**2010 ADAS Section: 213.3.1**

### **Recommendation:**

**Recommend adding signage indicating that no accessible restrooms are available and directing voters with disabilities to the front of the line. Alternatively, place a portable restroom in the parking lot.**

