

Accessibility Evaluation

Monroe County Polling Location



University Elementary
1111 N Russell Rd
Bloomington, IN 47408

Inspection Date: 03/23/2026
Inspectors: Michael Bird

Prepared By
Monroe County
(916) 473 - 9444

Report Date: 04/06/2026

Table of Contents

Findings	3
Exterior	3
Parking	3
Interior	4
Restrooms	4

Exterior: Parking

Finding: 1

The van space is missing the required van identification sign.

Parking space identification signs shall include the International Symbol of Accessibility. Signs identifying van parking spaces shall contain the designation "van accessible."

2010 ADAS Section 502.6

Parking space identification signs shall include the International Symbol of Accessibility complying with 703.7.2.1. Signs identifying van parking spaces shall contain the designation "van accessible." Signs shall be 60 inches (1525 mm) minimum above the finish floor or ground surface measured to the bottom of the sign.

Citation:

2010 ADAS Section: 502.6

Recommendation:

Recommend adding a temporary or permanent accessible parking sign.



Interior: Restrooms

Finding: 2

Two restrooms in the gym will be closed on Election Day. An accessible all-gender restroom near the exit will be available.

2010 ADAS Section 216.8

Where existing toilet rooms or bathing rooms do not comply with 603, directional signs indicating the location of the nearest toilet room or bathing room complying with 603 within the facility shall be provided. Signs shall comply with 703.5 and shall include the International Symbol of Accessibility complying with 703.7.2.1. Where existing toilet rooms or bathing rooms do not comply with 603, the toilet rooms or bathing rooms complying with 603 shall be identified by the International Symbol of Accessibility complying with 703.7.2.1. Where clustered single user toilet rooms or bathing facilities are permitted to use exceptions to 213.2, toilet rooms or bathing facilities complying with 603 shall be identified by the International Symbol of Accessibility complying with 703.7.2.1 unless all toilet rooms and bathing facilities comply with 603.

Citation:

2010 ADAS Section: 216.8

Recommendation:

Place signage informing voters that an accessible restroom is available near the exit and directing them to ask for assistance.

